**MARCH 2014** 


# SYNCHRONOUS & COGGED FAN BELTS

#### **OPPORTUNITY**

How much energy is used for ventilation in U.S. office buildings?

12% OF ELECTRICITY

GOES TO FAN VENTILATION<sup>1</sup>



### ADDITIONAL SAVINGS POSSIBLE

Belt-driven fans are also used in non-ventilation applications

### **TECHNOLOGY**

How do synchronous and cogged fan belts save energy?

### REDUCE FRICTION AND BENDING RESISTANCE

BY NOTCHING THE INNER SIDE OF THE BELT SYNCHRONOUS BELTS ALSO

**REDUCE SLIPPAGE** BY INTEGRATING TEETH WITH SLOTS ON THE MOTOR PULLEY

**2-5**% MORE EFFICIENT

THAN STANDARD V-BELTS

### M&V

Where did Measurement and Verification occur?

### RESULTS

How did synchronous and cogged fan belts perform in M&V? Gates Corporation at the Byron G. Rodgers Federal Building and U.S. Courthouse in Denver, Colorado

NATIONAL RENEWABLE ENERGY LABORATORY measured the

performance of cogged V-belts and synchronous drive belts provided by the

## 2-20% ENERGY SAVINGS

FOR SYNCHRONOUS ON VAV 2% AT 60 HZ, 20% AT 15 HZ Cogged fan belts on CV fans offered half the savings<sup>2</sup>

# **75**% LOWER 0&M

FOR SYNCHRONOUS Cogged 0&M equivalent to standard V-belts<sup>3</sup>

# <4 YEARS

PAYBACK FOR SYNCHRONOUS<sup>4</sup> Repeat installations have immediate payack; Cogged payback < 1 year <sup>5</sup>

### **Net Present Value as a Function of Electricity Rates & Fan Runtime**

Synchronous cost-effective at \$0.024/kWh or 6.8 hrs/day; Cogged cost-effective at \$0.15/kWh or 4.3 hrs/day



### DEPLOYMENT

Where does M&V recommend using synchronous and cogged fan belts?

## REPLACE V-BELTS WITH SYNCHRONOUS DRIVE BELTS ON ALL VAV FANS

Belts on fans with high operating hours should be replaced first

ON CV FANS, REPLACE V-BELTS AT END-OF-LIFE WITH COGGED V-BELTS

<sup>&</sup>lt;sup>1</sup>Synchronous and Cogged Fan Belt Assessment. Dylan Cutler, Jesse Dean, Jason Acosta (NREL), March 2014, p.1 <sup>2</sup>lbid, p.2 <sup>3</sup>lbid, p.3 <sup>4</sup>lbid, p.5 <sup>5</sup>lbid, p.4